


8" VALVE BOX CAP MARKED "WATER" (ALHAMBRA FOUNDRY NO. A-29606 OR APPROVED EQUAL) PAINTED BLUE

1/2" GROOVE AROUND CAP SEE DETAIL A (TYP.)

DEPTH TO OPERATING NUT



1/8" WELD
1/8" WELD

SLIP CHAMBER, 22 GAUGE GALVANIZED SHEET METAL, 12" LONG.

2" SQ. OPERATING NUT

8" SCHEDULE 40 PVC PIPE

7" O.D. x 3/16" PLATE. WELDED TO EXTENSION. (TYP)

VALVE STEM EXTENSION, 1-1/4" DIA. SOLID STEEL ROD FOR OPERATING NUT MORE THAN 4 FEET BELOW SURFACE.

2" SQ. OPERATING NUT

AC PAVEMENT

VALVE

SLIP CHAMBER

NOTE:

VALVE STEM EXTENSION SHALL BE PROVIDED WHERE DEPTH TO OPERATING NUT EXCEEDS 4'-0".

DETAIL A
NOT TO SCALE

ACCOMPANYING STD W-300 AND W-121

CITY OF LOMITA - PUBLIC WORKS DEPARTMENT

DATE ISSUED	VALVE BOX ASSEMBLY	STANDARD NO.
SEPT 1, 2007		W-150
DRAWN BY: SHIVDEV S. BRAR	WENDELL E. JOHNSON, CITY ENGINEER CERTIFICATION NO. C 66340 	SHEET 1 OF 1
DATE: AUG 14, 2007		